

Rotherham Schools

Discipline	Period	7. Meadowview	
		Current	
Water Quality Analysis (File 2)	QU	20/05/2019	
Fire Alarm System Maintenance (File 3)	A	31/07/2019	
Fire Door Inspection (File 3)	6M	18/04/2019	
Fire Dampers (File 3)	A	02/11/2019	
Sprinklers Quarterly (File 3)	QU	N/A	
Sprinklers 3 Yearly (File 3)	3Y	N/A	
Fire Extinguisher Maintenance (File 3)	A	07/08/2019	
Emergency Lighting (File 3)	A	03/01/2020	
Fixed Electrical Wiring Test (File 4)	5Y	25/08/2021	
Portable Appliance Tests (File 4)	A	21/02/2020	
Distribution Boards (File 4)	A	14/08/2019	
Lightning Conductor-11 Monthly (File 4)	11M	17/11/2019	
Ambirads	A	N/A	
Catering Equipment	A	29/06/2019	
Gas Fired W/Htr (File 5)	A	12/06/2019	
Gas Supplies and Installation (File12)	A	12/06/2019	
Gas Tightness Test (File 5)	5Y	13/03/2022	
Boiler Annual Service (File 5)	A	12/06/2019	12/06/2019
Kitchen Ventilation - Ductwork Inspection (File 7)	A	18/02/2020	
Lift maintenance (File 8)	QU	22/05/2019	
Insurance Inspection Passenger Lifts (File 8)	6M	22/08/2019	
Insurance Inspection Goods Lifts (File 8)	A	N/A	
Insurance Inspection Lifting Beam (File 8)	A	22/08/2019	
Insurance Inspection Hoist	6M	N/A	
Inspection Pressure Vessels (PSSR) (File 10)	26M	16/04/2020	
Pressure Release Valve Inspection (File 10)	26M	16/04/2020	16/04/2020
Insurance Fume Cupboard Inspection	A	N/A	
Insurance LEV Inspection	A	N/A	
Air Conditioning	A	30/07/2019	
Cable Based (Mansafe) Fall Protection	A		
Anchor Points (Eyebolts) Fall Protection	A	N/A	
Cold Rooms	A	N/A	